

Certification No. 1903

This is to certify that the metering equipment identified as:

Type: NIK 2307

Mgmt. Logical Device Name: SAP = 1 is "4E494B2032333037" (NIK 2307)

Manufactured by: NIK-Elektronika LLC

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 3.1 extended edition, 64bits, release 102
- Licensed to: 20171020_NIK-ELEKTRONIKA_LLC_Kyiv (20.10.2017)COSEM object definitions file version: Object_defs_v3.1_released_170313.dat
- Media identifier(s): Abstract, Electricity

Tests	Comm. profile & opening mode	Application contexts	Security features	Date and time	Test Result hash value
Test 1	HDLC, DIRECT_HDLC	LONG_NAMES	—	20-NOV-2017 14:09:09	D644603A8E265A9C3F147037FD1D9D02D D9004DE85DB37BB39CEF26BA33E2B6D
Test 2	HDLC, MODE_E	LONG_NAMES	—	20-NOV-2017 14:18:17	9621EB6C5B5476ED51E4E3625E3B196D51 50BA9C3FEBBAF61A9A09226DB46992

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: www.dlms.com.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested; see the Summary. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 22nd November 2017



Gyöző Kmethy
President

Certification No. 1903

Summary of features tested for Test 1

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****  
* Identification *  
*****
```

```
Identification = {  
  Manufacturer = "\NIK-Elektronika LLC"  
  FLAGid = "\NIK"  
  Type = "\NIK 2307"  
  FirmwareId = "\EMSW"  
  FirmwareVersion = "\EMxxx v.2.01"  
  ConfigurationId = "\NIK 2307"  
  SerialNr = "\2307100866782017"  
}
```

```
*****  
* Summary *  
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC	36	0	1	0	35	0
APPL	85	0	25	0	60	0
COSEM	1931	0	4	0	1927	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				

```
Communication profile:          HDLC  
  
Application context names:     LONG_NAMES  
  
Authentication mechanisms:     NO_SECURITY,LOW_LEVEL_SECURITY  
  
ACSE and xDLMS features:      GET,SERVICE_SPECIFIC_BLOCK_TRANSFER,SET  
  
Security features:             (not collected)  
  
Data protection features:      (not collected)  
  
Logical device(s) found:       SAP = 1 is "4E494B2032333037" (NIK 2307)  
  
COSEM classes tested:          1,3,8,15(1),17  
  
COSEM classes found but not tested: (none)
```

Certification No. 1903

Summary of features tested for Test 2

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****  
* Identification *  
*****
```

```
Identification = {  
  Manufacturer = "\NIK-Elektronika LLC"  
  FLAGid = "\NIK"  
  Type = "\NIK 2307"  
  FirmwareId = "\EMSW"  
  FirmwareVersion = "\EMxxx v.2.01"  
  ConfigurationId = "\NIK 2307"  
  SerialNr = "\2307100866782017"  
}
```

```
*****  
* Summary *  
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC		All (MODE_E)				
APPL	85	0	25	0	60	0
COSEM	1931	0	4	0	1927	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				

```
Communication profile:          HDLC  
Application context names:     LONG_NAMES  
Authentication mechanisms:     NO_SECURITY,LOW_LEVEL_SECURITY  
ACSE and xDLMS features:      GET,SERVICE_SPECIFIC_BLOCK_TRANSFER,SET  
Security features:             (not collected)  
Data protection features:      (not collected)  
Logical device(s) found:      SAP = 1 is "4E494B2032333037" (NIK 2307)  
COSEM classes tested:         1,3,8,15(1),17  
COSEM classes found but not tested: (none)
```