

Certification No. 2014

This is to certify that the metering equipment identified as:

Type: NIK 2100 **FirmwareId = "\EMSW"** **FirmwareVersion = "\EMxxx_v.2.02"**

Mgmt. Logical Device Name: SAP = 1 is "4E494B2032313030" (NIK 2100)

Manufactured by: NIK-Elektronika LLC

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 3.1 standard edition, 64bits, release 106
- Licensed to: 20171020_NIK-ELEKTRONIKA_LLC_Kyiv (20.10.2017)
- COSEM object definitions file version: Object_defs_v3.3_released_180601.dat
- Media identifier(s): Abstract, Electricity

Tests	Comm. profile & opening mode	Application contexts	Security features	Date and time	Test Result hash value
Test 1	HDLC, MODE_E	LONG_NAMES	—	16-SEP-2018 14:04:13	68A88F57F3E6FF39C383761E75868D4A966 C7E0BE3E46818B65D5C83FD19367E

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: www.dlms.com.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested; see the Summary. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Zug, the 17th September 2018



Gyöző Kmethy
President

Certification No. 2014

Summary of features tested for Test 1

This section provides an overview of the features tested, aggregated over all logical devices and Application Associations in one test session. Full information is available in the Test Result.

```
*****  
* Identification *  
*****
```

```
Identification = {  
  Manufacturer = "\NIK-Elektronika LLC"  
  FLAGid = "\NIK"  
  Type = "\NIK 2100"  
  FirmwareId = "\EMSW"  
  FirmwareVersion = "\EMxxx_v.2.02"  
  ConfigurationId = "\NIK 2100"  
  SerialNr = "\2100276457822018"  
}
```

```
*****  
* Summary *  
*****
```

TYPE	TOTAL	SKIPPED	INAPPLICABLE	INCONCLUSIVE	PASSED	FAILED
----	-----	-----	-----	-----	-----	-----
HDLC		All (MODE_E)				
APPL	71	0	22	0	49	0
COSEM	1055	0	3	31	1021	0
SYMSEC		All (No ciphered association with the required properties)				
PUBSEC		All (No ciphered association with the required properties)				
DP	0	0	0	0	0	0
GBT		All (No association with the required properties)				

```
Communication profile:          HDLC  
Application context names:     LONG_NAMES  
Authentication mechanisms:     NO_SECURITY,LOW_LEVEL_SECURITY  
ACSE and xDLMS features:      GET,SERVICE_SPECIFIC_BLOCK_TRANSFER,SET  
Security features:             (not collected)  
Data protection features:      (not collected)  
Logical device(s) found:      SAP = 1 is "4E494B2032313030" (NIK 2100)  
COSEM classes tested:          1,3,5,7(1),8,15(1),17,19(1),23(1),43  
COSEM classes found but not tested: (none)
```